



Institute for
Wastewater
Technology

PERFORMANCE RESULTS

Bord Na Móna Environmental Ltd

Main Street
Newbridge
Co. Kildare
Ireland

EN 12566-1

„Small wastewater treatment systems for up to 50 PT“

Part 1: Prefabricated septic tanks

APG6

Material	Glass reinforced plastic
Watertightness (Annex A)	passed
Nominal capacity (Annex A)	3 m ³
Hydraulic efficiency (Annex B)	> 99,99 %
Structural behaviour (Annex C.5)	passed

Performance tested by:

PIA - Prüfinstitut für Abwassertechnik GmbH

(PIA GmbH)

Hergenrather Weg 30

D-52074 Aachen

Certified according to
ISO 9001:2000



Notified Body number: 1739



This document replaces neither the declaration
of conformity nor the CE marking.

Prüfinstitut für Abwassertechnik GmbH

geprüft - tested - testé

Elmar Lancé

August 2010